



#### NOTES

1. USE MIDWEST SERVICE ENTRANCE RATED LOAD CENTER WITH INTEGRAL RING TYPE METER BASE MODEL #M101CP6. (OR EQUAL) LOAD CENTER MUST BE NEMA 3R & SERVICE ENTRANCE RATED. PROVIDE (1) 40 AMP SINGLE POLE & (1) 20 AMP DOUBLE BRANCH CIRCUIT BREAKERS. ALL BREAKERS MUST BE UL LISTED FOR USE IN THE LOAD CENTER.
2. USE MIDWEST (OR EQUAL) EXTERNAL GROUND LUG, MODEL #GL-6.
3. USE MIDWEST (OR EQUAL) FOOTING BASE, MODEL #FBEM9.



## SERVICE CABINET DETAIL

#### CIVIL & UTILITY ENGINEERING

APPR. BY: PKR

DATE: 11.22

DRAWN BY: LD

DWG: TR13

CAD FILE: 2022\_TR13\_11\_2022